

CERTIFICATE OF COMPLIANCE

Certificate Number E123842
Report Reference E123842-19891110
Date 2021-April-05

Issued to: METRIX INSTRUMENT CO
8824 Fallbrook Dr
Houston TX, 77064-4855 US

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS;
PROCESS CONTROL EQUIPMENT FOR USE IN ZONE
CLASSIFIED HAZARDOUS LOCATIONS
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: See addendum for standards.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



METRIX DOC NO: 1917240
REV: A

CERTIFICATE OF COMPLIANCE

Certificate Number E123842
Report Reference E123842-19891110
Date 2021-April-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Class I, Division 1, Groups A, B, C and D Hazardous Locations.
USL - Class I, Zone 0, AEx ia IIC Hazardous Locations.
CNL - Ex ia IIC Ga Hazardous Locations.


Velocity Transducer Model 5485C, intrinsically safe when wired per Metrix Control Drawing 7623.

USL, CNL - Class I, Div. 2, Groups A, B, C and D.

Velocity transducer, Model 5485C for use in Class I, Division 2, Groups A, B, C and D hazardous locations when wired to a nonincendive field circuit per Metrix Drawing 8096.

Standards for Safety:

UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and @ Hazardous (Classified) Locations
CAN/CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and @ Hazardous (Classified) Locations
UL 61010-1, Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements
CAN/CSA C22.2 No. 61010-1, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use – Part 1, General Requirements
UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations
CAN/CSA-C22.2 No. 60079-0:19, Explosive atmospheres — Part 0: Equipment — General requirements
CAN/CSA-C22.2 No. 60079-11:14, Explosive atmospheres — Part 11: Equipment protection by intrinsic safety “i”
UL 60079-0:20, Explosive atmospheres — Part 0: Equipment — General requirements
UL 60079-11:13, Explosive atmospheres — Part 11: Equipment protection by intrinsic safety “i”



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



METRIX DOC NO: 1917240
REV: A