



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEX Scheme visit www.iecex.com

Certificate No.: **IECEX BAS 12.0033X** Page 1 of 4 Certificate history:
Issue 0 (2015-07-16)

Status: **Current** Issue No: 1

Date of Issue: 2019-10-25

Applicant: **Metrix Instrument Company**
8824 Fallbrook
Houston
Texas 77064
United States of America

Equipment: **MX2032, MX2033 & MX2034 Digital Proximity Systems**

Optional accessory:

Type of Protection: **Type n**

Marking: **Ex nA IIC T4 Gc (-40°C ≤ Ta ≤ +85°C)**
Supply = 17 to 30V d.c.

Approved for issue on behalf of the IECEX
Certification Body:


R S Sinclair

Position:

Technical Manager

M POWNEY
Certification
Manager

Signature:
(for printed version)


28/10/19

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

SGS Baseefa Limited
Rockhead Business Park
Staden Lane
Buxton, Derbyshire, SK17 9RZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 12.0033X**

Page 2 of 4

Date of issue: 2019-10-25

Issue No: 1

Manufacturer: **Metrix Instrument Company**
8824 Fallbrook
Houston
Texas 77064
United States of America

Additional manufacturing locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2011 Explosive atmospheres - Part 0: General requirements
Edition:6.0

IEC 60079-15:2010 Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition:4

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/BAS/ExTR12.0040/00](#)

[GB/BAS/ExTR18.0206/00](#)

Quality Assessment Report:

[GB/BAS/QAR10.0017/06](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx BAS 12.0033X**

Page 3 of 4

Date of issue: 2019-10-25

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The MX2032, MX2033 and MX2034 are normally supplied as part of the Digital Proximity System (DPS). The units comprise three potted printed circuit boards housed inside a DIN rail mountable enclosure. A coaxial RF connector is present to enable a proximity probe to be connected using an extension cable, and a 3 or 4 way terminal block accepts the user connections.

The MX2034-AA-BB-CC-DD-EE-FF where EE = X4, X5 or X6 includes connections for a dynamic output signal on the 4 way connector. All other variants have a 3 way connector present.

Rated supply voltage = 17V to 30V.

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The protection concept used must be irrevocably marked on the label during installation, except for the MX2034-AA-BB-CC-DD-EE-FF where EE = X4 X5 or X6 that is marked as "nA" during manufacture.
2. The equipment must be installed in a suitably certified enclosure such that it is afforded a degree of protection of at least IP54 in accordance with EN 60529 and EN 60079-15 and is in an area of not more than pollution degree 2, as defined in IEC/EN 60664-1.
3. External transient supply limitation must be present that clamps at no more than 42V.
4. Do not separate connectors when energised.



IECEx Certificate of Conformity

Certificate No.: **IECEx BAS 12.0033X**

Page 4 of 4

Date of issue: 2019-10-25

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Variation 1.1

To permit minor electrical changes, the addition of the model MX2034-AA-BB-CC-DD-EE-FF (where EE = X4 X5 or X6) that has a dynamic signal output capability, and minor drawing changes.

ExTR: **GB/BAS/ExTR18.0206/00**

File Reference: **18/0441**



The following pages are the prior revisions of this certificate.



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx BAS 12.0033X issue No.:0 Certificate history:

Status: Current

Date of Issue: 2015-07-16 Page 1 of 3

Applicant: **Metrix Instrument Company**
8824 Fallbrook, Houston, Texas 77064
United States of America

Electrical Apparatus: **MX2032, MX2034 & MX2033 Digital Proximity Systems**
Optional accessory:

Type of Protection: **Type n**

Marking: **Ex nA IIC T4 Gc (-40°C ≤ Ta ≤ +85°C)**
Supply = 17 to 30V d.c.

Approved for issue on behalf of the IECEx Certification Body: R S Sinclair

Position: Technical Manager

Signature:
(for printed version)



16-7-15

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

SGS Baseefa Limited
Rockhead Business Park
Staden Lane
Buxton
Derbyshire
SK17 9RZ
United Kingdom





IECEx Certificate of Conformity

Certificate No.: IECEx BAS 12.0033X

Date of Issue: 2015-07-16

Issue No.: 0

Page 2 of 3

Manufacturer: **Metrix Instrument Company**
8824 Fallbrook, Houston, Texas 77064
United States of America

Additional Manufacturing location
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements
Edition: 6.0

IEC 60079-15 : 2010 Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition: 4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:
[GB/BAS/ExTR12.0040/00](#)

Quality Assessment Report:
[GB/BAS/QAR10.0017/03](#)



IECEx Certificate of Conformity

Certificate No.: IECEx BAS 12.0033X

Date of Issue: 2015-07-16

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The MX2032, MX2033 and MX2034 are normally supplied as part of the Digital Proximity System (DPS). The units comprise three potted printed circuit boards housed inside a DIN rail mountable enclosure. A coaxial RF connector is present to enable a proximity probe to be connected using an extension cable, and screw terminal plug and socket assembly accepts the user connections. The MX2034 also includes a BNC connector for dynamic output.

Rated supply voltage = 17V to 30V.

CONDITIONS OF CERTIFICATION: YES as shown below:

1. The protection concept used must be irrevocably marked on the label during installation.
2. The equipment must be installed in a suitably certified enclosure such that it is afforded a degree of protection of at least IP54 in accordance with EN 60529 and EN 60079-15 and is in an area of not more than pollution degree 2, as defined in IEC/EN 60664-1.
3. External transient supply limitation must be present that clamps at no more than 42V.
4. Do not separate connectors when energised.

METRIX DOC NO: 1456015
REV: A